

October 16, 1979

NOTE:  
COMPANY  
MOVED OUT OF  
BUILDING.  
SDS

Commercial Plastics Company  
514 East Commercial  
Springfield, Mo.

Dear Sirs:

On a recent inspection personnel from the City's Water Pollution Control Section observed a discharge from your property.

The inspection revealed two sinks that were tributary to a floor drain. The floor drain in question terminates in the alley behind 514 East Commercial.

Please be advised that a discharge of wastewater as noted above is in violation of City, State, and Federal Water Pollution Control Laws, and in violation of City Health Ordinances. This office advises you to cease discharge immediately, and to dispose of such waste in a proper waste treatment system.

If this office can be of service to you in answering any questions, please do not hesitate to call.

Yours truly,

Stephen Short  
Water Pollution Control Inspector II  
Surveillance and Enforcement

SS/js

cc: Roger Taylor

514 E. Commercial